

Office of the District Fire Officer
Karnataka State Fire
and Emergency Services
Khanapur Road, Belagavi-590001



Phone : 0831-2429441
E-Mail : dfobgv@gmail.com

C.NO/195/FSCR/DFO/BELAGAVI/2026

Date :20-06-2026

To,
The President,
Shri Mallikarjun Foundation's
Shri S M Naragund International School
Vijayapur Road, Athani, Athani Taluk & Belagavi District.

Sir,

Sub : Issue of '**Fire Safety Compliance Report**' to Shri Mallikarjun Foundation's Shri S M
Naragund International Vijayapur Road Athani, Athani Taluk & Belagavi District
Ref: 1.C.NO/98/FSCR/FSO/ATHANI/2026. Date: 19-06-2026.
2.Applicant Request Letter Dated:-16-06-2026

*_*_*_*_*_*_*_*_*_*

With reference to the subject above cited, the premises of Shri Mallikarjun Foundation's Shri S M. Naragund International School building consisting with Ground & 1 Upper floor situated at **Vijayapur Road Athani, Athani Taluk Belagavi District** was inspected by Fire Station Officer, Athani on 18-06-2026 with respect to fire Prevention, Fire Fighting & Evacuation point of view for the purpose of issuing **Fire Safety Compliance Report** and has submitted the details as under.

ANNEXURE-1

"GROUP-B Educational Buildings

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.
(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the Building/Premises.

01.	Name and Address of the Applicant	The President, Shri Mallikarjun Foundation's Shri S M Naragund International School Vijayapur Road Athani, Athani Taluk & Belagavi District.
02.	Name and Address of the Premises	Shri Mallikarjun Foundation's Shri S M Naragund International School Vijayapur Road Athani, Athani Taluk & Belagavi District.
03.	Name and Address of the Building Owner	Shri Vivekanand. Shrishail Naragund. At/Post : Shegunashi, Taluk Athani, Dist: Belagavi
04.	Number of Building	01
05.	Number of Floors	Ground & One Upper Floor
06.	Floor-wise details of Occupancy:-	
	Ground Floor	Class Rooms-14 Office-02
	1 st Floor	Class Room-14, Office-01, Computer Lab-01 Library-01 Science Lab-01
07.	Height of the building	07.45 Mtr
08.	Site area	25794.33 Sq. Mtr.
09.	Built-up area of each floor:-	

	Ground Floor	1278.96 Sq Mtrs
	1 st Floor	1332.52 Sq Mtrs
10.	Total Built-up area	2611.48 Sq Mtrs
11.	Surrounding properties:-	
	East	Agricultural Land
	West	Residential Layout
	North	Athani-Vijaypur Road
	South	Agricultural Land
12.	Open Space all around the building	
	East	05.00 Mtr
	West	02.80 Mtr
	North	110.00 Mtr
	South	243.00 Mtr
	Allowed Setbacks (open space) should be maintained free from further obstruction/construction.	

B. On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-

from fire safety point of view:-				
Sl. No	Details (02)	Existing (03)		Recommendations (04)
01.	Accessibility to the premises	Accessibility from Southern side with 07.00 Mtr wide road on Northern side		Adequate
02.	Number of Entrances	02 Entrance each of 04.50 Mtr Wide		Adequate
03.	Number of Staircase	No of staircase	04 no.s Each	Complied
		Width of the staircase	04.40 mtr	
		Width of threads	0.25 mtr	
		Height of risers	0.15 mtr	
		No of risers per flight	11	
		Height of the hand drill.	01.00 mtr	
		Head room clearance	2.80 mtr	
04.	Portable Extinguishers	14 nos. of 6 Kg capacity ABC type & 02 no. of 4.5 Kg capacity CO2 type extinguisherhas been provided. All the extinguishers suggested are BIS markings and are located at an easily accessible position without obstructing the normal passage.		Complied
05.	Escape routes	Direction in which the students/teachers have to move in the event of emergency has been indicated in the corridor/passage as a guide during evacuation.		Complied.
06.	Fire Order (Fire safety plans)	A notice board indicating the action to be taken by the employees in case of any emergency has been displayed along with the telephone numbers of Athani Fire Station i,e 08289-251740, & 101,112 the telephone nos nearest ambulance services and police station.		Complied
07.	No Smoking board	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board is written in the English & Kannada both languages and is displayed inside the entry/exit.		Complied

	Fire Siren	A fire siren has been installed in the premises to inform the students/teachers in case of a fire emergency and evacuate the area.	Complied
09.	Nominate One Fire Nodal Officer	01) Shri Shri Shrinivas Kavatkoppa 02) Shri Shivanand Naragund Are Nominated as fire Nodel Officer	Nominated
10.	Fire Fighting Training	01) Shri Shri Shrinivas Kavatkoppa 02) Shri Shivanand Naragund Two Persons are got Trained in Basic Fire Fighting at \ Fire Station Office Premises	At least 40% of the Teaching and non Teaching staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre.
15.	<u>Fire Precautionary Measures</u> A :- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises. B:-Accumulation of combustible waste in and around the premises should be avoided. C:- The Exit ways shall be always kept clear without any obstruction. D:-Liquefied petroleum gas should not be stored in the building. E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction. F:- During the class hours the class room door shall not be locked from inside to out side. G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14 th of every year by conducting Fire Safety drills with co-ordination with the fire services department.		

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "Fire Safety Compliance Report" to Shri. Mallikarjun Foundation's Shri S M. Naragund International School Vijaypur Road, Athani, Athani Taluk & Belagavi District. As they have complied all the recommendations as per reference 1. The staff should get trained in the basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre Hubballi.

This "Fire Safety Compliance Report" is valid for only one year from the date of issue and is renewable.

Yours Faithfully

[Signature]
District Fire Officer
Karnataka State Fire And Emergency Services
Belagavi-01



[Signature]
Principal
Shri S M Naragund
International School
Athani-591304

[Signature]
President
Shri Mallikarjun Foundation
Shegunashi-591220
Tq:Raibag Dist: Belagavi.